

Accessibility Guidelines Checklist for Existing Trails Adapted by the Arkansas Disability & Health Program

Trail Name: _____ Date of Visit: _____

City: _____

Accessibility Ambassadors, please answer the questions on the survey and feel free to add comments or pictures as needed.

Parking	Yes	No
1. Is the trail identified by signage as being accessible to individuals who have disabilities?	<input type="checkbox"/>	<input type="checkbox"/>
2. Are accessible parking spaces available? (They should be closest to the trailhead entrance).	<input type="checkbox"/>	<input type="checkbox"/>
3. Are accessible parking spaces 96 inches wide with an access aisle way of 60 inches wide beside it?	<input type="checkbox"/>	<input type="checkbox"/>
4. Is the access aisle way part of an accessible route to the trailhead?	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>
5. Is the surface of the parking lot level and made of a hard, non-skid surface?	<input type="checkbox"/>	<input type="checkbox"/>
6. Are the accessible parking spaces designated as reserved for people with disabilities by a sign showing the international symbol of accessibility?	<input type="checkbox"/>	<input type="checkbox"/>

7. Are there directional signs indicating the location of accessible entrances, parking, restrooms, and other accessible facilities?	<input type="checkbox"/>	<input type="checkbox"/>

Restrooms	Yes	No
1. Is the doorway to the restroom at least 32” wide?	<input type="checkbox"/>	<input type="checkbox"/>
2. Is there an accessible toilet stall?	<input type="checkbox"/>	<input type="checkbox"/>
3. Is the door on the accessible stall at least 32” wide and equipped with handles that are operable with a closed fist?	<input type="checkbox"/>	<input type="checkbox"/>
4. Does the accessible restroom have soap and paper towels within arm’s reach of a seated position?	<input type="checkbox"/>	<input type="checkbox"/>

Signage Maps & Guides	Yes	No
1. Does signage provide information on the length of the trail or trail segment, surface type, tread width (typical/minimum), and running and cross slope?	<input type="checkbox"/>	<input type="checkbox"/>
2. Is trail signage/maps/guides located at the edge of the trail, and do not protrude into accessible route of travel?	<input type="checkbox"/>	<input type="checkbox"/>

Trail Features	Yes	No
1. Is the trail paved and free of barriers on the path?	<input type="checkbox"/>	<input type="checkbox"/>
2. Is the trail wide enough for a person to pass another person, while using a wheelchair?	<input type="checkbox"/>	<input type="checkbox"/>
3. If not, are trail passing spaces available?	<input type="checkbox"/>	<input type="checkbox"/>
4. Are passing spaces placed at the maximum interval of every 300 feet?	<input type="checkbox"/>	<input type="checkbox"/>
5. Is there vertical clearance of 80 inches – the clear head space over the accessible route?	<input type="checkbox"/>	<input type="checkbox"/>
1.		

Miscellaneous Notes: _____

Survey completed by: _____

